



OFFICE OF THE DEPUTY FIRE OFFICER,
ANGUL CIRCLE, ANGUL, PIN-759122

Tel.No: 06764-232444, Mob No: 7655072548 (CUG) Email ID: dfoangulcircle@gmail.com

Letter No.345/Angul Circle

Date:08.05.2025

To

The Headmistress, DAV Public School,
MCL, Lingaraj Area, Talcher, At/PO-Deulbera Colliery, Dist-Angul

Sub: Regarding issue of Fire Safety Certificate in favour of DAV Public School
MCL, Lingaraj Area, Talcher, At/PO-Deulbera Colliery, Dist-Angul
vide plot no.995, Khata No.335, Mouza -Deulbera, Dist-Angul.

(This letter valid up to.07.05. 2027)

Sir,

With reference to the subject cited above it is to intimate that, earlier this office have received an application through online agnishamaseva portal vide application of educational building No. FSC13051400720250000010 in favour of DAV Public School, MCL, Lingaraj Area, Talcher, At/PO-Deulbera Colliery, Dist-Angul for issuance of fire safety certificate. After going through scrupulous scrutiny the application it is found that this educational building DAV Public School, MCL, Lingaraj Area, Talcher, At/PO-Deulbera Colliery, Dist-Angul has been constructed in built up area 780 Sqmt. As per rule-9(1) (i) of Odisha Fire Prevention and Fire safety rule-2017 read with Odisha fire prevention and fire safety rule amendment rule-2019 categorized as educational establishment as mentioned below required fire safety certificate.

1. Building height is having 12 mtrs and above, or
2. Having a built up area of 1000 sqmtrs or above,
3. Having three storied building.

As such the above mention Ground floor educational building having height 3.5 mtrs and total built up area 780 sqmt is not required fire safety certificate.

However, it is to instructed that the fire prevention and fire safety measure will be taken as per NBCI-2016, you are requested to have provisions as mention below.

If any further construction is required to be made, please intimate this office before commencement of the construction work for furtherance at this end.

Occupier should be approved building plan from concerned development authority, staff & students needs to be trained periodically to make them well-conversation in use of the fire fighting equipment's for there operation during the time of any emergency.

Dij

महा प्रबंधक
एम्. सी. एल., लिंगराज क्षेत्र
General Manager
M.C.L. Lingaraj Area

S. S. S.

Headmistress
DAV PUBLIC SCHOOL
MCL, LINGARAJ AREA

U. S. S.
8/5/25

Deputy Fire Officer
Angul Circle, Angul